



Mary Ann Manges <mmanges@amadorgov.org>

Fwd: Loop Road Drainage Issues

Chuck Beatty <CBeatty@amadorgov.org>
To: Mary Ann Manges <mmanges@amadorgov.org>

Wed, Sep 7, 2022 at 11:40 AM

Additional comments for Friday's Tri-TAC meeting.

----- Forwarded message -----

From: **Rick Ansel** <ransel@kmpud.com>
Date: Wed, Sep 7, 2022 at 11:22 AM
Subject: Loop Road Drainage Issues
To: Chuck Beatty (<cbeatty@amadorgov.org>) <cbeatty@amadorgov.org>
Cc: Erik Christeson <EChristeson@kmpud.com>, Brandi Benson <bbenson@kmpud.com>

Chuck,

For your reference and consideration. Yesterday afternoon we had a brief rainstorm that passed over the Kirkwood area. The attached photos illustrate the storm water drainage issues on Loop Road that impact our facilities located along the roadway and drive/parking areas around the Community Service Building-Fire Station. Essentially due to road design, lack of proper drainage or regular maintenance of existing drainage on Loop Road. Storm water runs down and across Loop road into the entrance of the CSB-Fire Station and the District's Vehicle Maintenance buildings.

The District is concerned the addition of the proposed new parking spaces along Loop Road will only exacerbate the problem and the current parking plans designs fail to properly address these issues.

Sincerely,

Rick Ansel

Assistant General Manager

Kirkwood Public Utility District

Office (209) 258-4444 Ext. 103

Cell (775) 781-2505

Kirkwood Meadows PUD is an equal opportunity provider and employer.

--

Chuck Beatty, AICP
Planning Director
Amador County
209-223-6380

5 attachments



Loop Road 9.6.22 # 1.jpg
1670K



Loop Road 9.6.22 #2.jpg
1383K



Loop Road Drainage Issue 9.6.22 #3.jpg
1543K



Upper 7 9.6.22.jpg
1727K



CSB Drainage Runoff Issue 6.23.2020.jpg
2676K





KIRKWOOD
COMMUNITY
SERVICES

000
432
000





