BEFORE THE BOARD OF SUPERVISORS OF THE COUNTY OF AMADOR, STATE OF CALIFORNIA

IN THE MATTER OF:

RESOLUTION APPROVING A VARIANCE TO AMADOR)	RESOLUTION NO. 10-013
COUNTY CODE SECTION 14.06.010 TO ALLOW REDUCED)	
SETBACKS FROM A BUILDING SEWER AND PUMP)	
STATION TO A WATER WELL LOCATED ON ASSESSOR'S PARCEL NUMBER 042-020-004-000)	
)	

WHEREAS, owner of Assessor's Parcel Number 042-020-004-000 has constructed a pump station within 21 feet of the existing water supply well and a building sewer within 5 feet of said well; and

WHEREAS, setbacks established in code specify a minimum setback of 100 feet from the pump station to the well and 25 feet from the building sewer to the well; and

WHEREAS, the owner agrees to pressure test the pump station and building sewer to verify water tightness and further agrees to record a document describing the details of the installation and the variance; and

WHEREAS, the designer of the on-site sewage system does not object to the variance

NOW, THEREFORE, BE IT HEREBY RESOLVED that the Board of Supervisors of the County of Amador, does hereby grant a variance to Amador County Code Section 14.06.010 to allow the existing structures to remain as constructed provided said structures are demonstrated water tight via a pressure test satisfactory to the Environmental Health Department and that the details of this construction and variance be described in a recorded constructive notice document which is intended to assure accurate disclosure to future owners of Assessor's Parcel Number 042-020-004-000.

The foregoing resolution was duly passed and adopted by the Board of Supervisors in the County of Amador at a regular meeting thereof, held on the 2nd day of February, 2010, by the following vote:

AYES: Brian Oneto, John Plasse, Richard M. Forster, Theodore F. Novelli, Louis D. Boitano

NOES: None

ABSENT: None

Vice Chairman, Board of Supervisors

ATTEST:

Jennifer Burns, Clerk of the

Board of Supervisors, Amador County,

California <

Deputy